



REPUBLIC OF THE PHILIPPINES
**PUBLIC-PRIVATE PARTNERSHIP
CENTER**

August 20, 2015

SPECIAL BIDS AND AWARDS COMMITTEE
BID BULLETIN NO. 1
Series of 2015

SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF BACKUP POWER SUPPLY

TO ALL PROSPECTIVE SUPPLIERS:

Please find herewith the responses to the clarifications raised by prospective suppliers:


Item No.	Reference	Questions/Clarifications	PPPC Response
1	Request for Quotation	<p>In preparation to our bid document, we will appreciate very much if you can advise us of what other pertinent documents should we need to accomplish and will include in the submission aside from:</p> <ul style="list-style-type: none">- Technical Compliance Table- Data Sheets (Technical documents and catalogues)a. General Description- After-Sales Service Support and List of Facility in the Philippines- Other information as stated on "Qualifications of the Supplier"	<p>Please note that this procurement is through "Shopping" and not competitive bidding. For the purpose of evaluating proposals, we will only need the following submissions:</p> <ul style="list-style-type: none">- Duly accomplished Form of Quotation- Technical documentation and catalogues- List of firms providing after-sales service in the Philippines
2	Request for Quotation	<p>Kindly confirm if there's a need for us to provide the following requirement as part of our submission to PPP:</p> <ul style="list-style-type: none">- Eligibility documents (SEC, Mayor's permit, Audited Financial	<p>No need. Please refer to the response above.</p>

		<p>Statements, Tax Clearance</p> <ul style="list-style-type: none"> - Do we need to sign on the "Form of Contract", or this document only after the receipt of NOA/NTP? - Do we also need to submit compliance on the "Terms and Condition of Supply" 	
3	Request for Quotation	We understand that the ABC is intended for the two (2) lots as mentioned on the inquiry, can we request for the individual ABC for each Projects required?	Please note that both lots constitute one contract. Thus you must quote for both lots. There are no individual ABCs for each lot.
4	Interface ports: DB-9 (RS-232), RJ-45 10/100 Base-T, Smart slot	<p>Can we replace the DB-9 (RS-232) port requirement to USB port? Refreshed UPS model compliant to PPP requirement has no longer DB-9 (RS-232) port. The available ports on the refreshed model are <u>RJ-45 10/100 Base-T</u>, <u>RJ-45 Serial</u>, <u>Smart-Slot</u>, <u>USB</u>.</p> <p>Can a USB port suffice and an intellislot port that can be plugged with SNMP card with RJ-45 10/100 Base-T?</p>	The bidder may offer the equivalent or latest technology available.
5	Rack height: 3U (maximum)	<p>Is this a typographical error? The form factor of the compliant UPS model is 4U Rack.</p> <p>Is the 3U height a strict specs? Can we not propose 4U or 5U brand?</p>	<p>As stated in the technical specification the 3U (maximum) rack height must be complied. This is not a typographical error.</p> <p>The 3U (maximum) rack height refers to the main unit, not including the extended battery.</p>
6	Output Frequency: 50/60Hz +/-3 user adjustable +/- 0.1	Is the user adjustable feature a must comply specs because equipment requires 50 or 60Hz thus adjusting the UPS output frequency in not normally done and will only cause mismatch to the equipment to be plugged in the UPS?	As stated in the technical specification the 50/60Hz +/-3 user adjustable +/- 0.1 is required.

	Output Connections: Must Have at least a minimum of 4 IEC 320 C19	Since we will supply vertical power strips, the devices may just connect to the power strip and no longer to the output sockets of the UPS	As stated in the technical specification the four (4) minimum IEC 320 C19 must be part of the UPS.
--	--	--	---

Please note that we will not entertain further requests for clarification from today.

For information



FIDEL T. UDARBE

Chairperson, Special Bids and Awards Committee