



REPUBLIC OF THE PHILIPPINES
PUBLIC-PRIVATE PARTNERSHIP
CENTER

SPECIAL BIDS AND AWARDS COMMITTEE

FOR THE PROCUREMENT OF IT HARDWARE AND SOFTWARE
UNDER ADB - CDTA 7796

BID BULLETIN NO. 2
SERIES OF 2016

SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF
FIRE PROTECTION FOR THE DATA CENTER

TO ALL PROSPECTIVE SUPPLIERS:

Please find herewith the responses to your queries on the Requests for Quotation (RFQ) documents.

No.	Reference	Queries	PPPC Response
1	Terms of Reference Technical Specification	Are you considering installing other nozzle beneath the raised flooring?	The nozzle must be distributed above and beneath the raised flooring for maximum fire protection coverage.
2	Form of Contract	Is the form of contract included in the submission?	No, the Form of Contract is not included in the submission.
3	Terms of Reference Section V. Responsibility of the Supplier	Is subcontracting allowed?	We will only allow subcontracting for the installation and commissioning works. For this purpose, and in relation to Section III of the Terms of Reference on "qualification of bidders", the subcontractor must have at least 3 years' experience in the installation and commissioning works of fire protection equipment, and must submit Certificate of Satisfactory Service on completed projects or any equivalent document from at least 2 clients in the past 3 years. The bidder, must on the other hand, have at least 3 years' experience in the supply and delivery of fire protection equipment, and must submit Certificate of Satisfactory Service on completed projects or any equivalent document from at least 2 clients in the past

			<p>3 years.</p> <p>Notwithstanding subcontracting of the installation and commissioning works, the bidder/supplier shall be held responsible for the work of its subcontractor. (Please refer to item 3(e), Section V of the Terms of Reference)</p>
4	<p>Terms of Reference</p> <p>Qualification of the Bidders</p>	<p>Can we submit a certificate from our Distributor/Partner that they authorized and support our company, instead of re-sellership?</p>	<p>Please refer to the form of certification required under Item 1, Section III of the Terms of Reference. We will only allow authorized distributors, authorized re-seller or authorized dealers, of fire protection equipment.</p>
		<p>Can we utilize certification of engineers coming from our Distributor/Partner?</p>	<p>Certified engineers of the distributor/partner may be accepted, as long as the bidder has access to the services being provided by such engineers. For this purpose, the bidder must also submit a certification from its distributor/partner that they will provide after-sales service and maintenance support for the goods supplied by the bidder/supplier. Notwithstanding, the supplier shall remain responsible for maintenance support and/or repair on product defects.</p>
		<p>Can we submit partner's certificate of satisfactory service?</p>	<p>Please refer to our response in Item 3 above.</p>

The PPP Center will no longer accept further queries after the issuance of this Bid Bulletin.

For your information.


FEROISA FRANCISCA T. CONCORDIA
 Chairperson
 Special Bids and Awards Committee

April 14, 2016